



Checklist for Extreme Unit

Is there a red alarm on the display?	Yes	No
Is there ice on the evaporator coil?	Yes	No
If so, is the evaporator fan running?	Yes	No
Is the probe inserted into a bottle of water?	Yes	No
Is the unit leaking water? <i>If so, check the drain line access on the side of the unit and the drain line to ensure neither are obstructed.</i>	Yes	No
Is the unit tilted back?	Yes	No
Is the unit cooling?	Yes	No
If the unit is not cooling, is the condensor fan on? <i>If not, the fan may have malfunctioned. If both evaporator and condenser fans are not on and the unit is giving a call for cooling, then it may be a controller issue. NOTE: Older versions of the Extreme units may operate differently.</i>	Yes	No